



Control Valve
 Check Valve

DETAIL NOT TO SCALE

FIRE PUMP ISOMETRIC

FIRE PROTECTION

Detail FP-7

Town of Hope Mills, North Carolina

February 28, 2015 Original



NOTES:
 HYDROSTATIC TEST ALL PIPING PER NFPA 13.
 PUMP TEST HEADER IS REQUIRED.
 FLOW METER IS OPTIONAL.
 NOTES 1,2,4&5 SEE NFPA 20, A-2-14