


# SPRINKLER LEGEND

○	EXISTING SPRINKLER	1/2" / 155° / SSP / 5.6K / TOTAL	250 /
R⊗	EXISTING SPRINKLER TO BE REMOVED & PLUGGED	___ / ___ / ___ / ___ / TOTAL	10 /
○	EXISTING SPRINKLER TO BE RELOCATED	___ / ___ / ___ / ___ / TOTAL	30 /
●	NEW CHROME PENDENT SPRINKLER VIKING FAST-RESPONSE MODEL M WITH MODEL F1 CHROME ESCUTCHEON	1/2" / 155° / SSP / 5.6K / TOTAL	16 /
○	NEW BRASS UPRIGHT SPRINKLER CENTRAL MODEL A	3/4" / 165° / SSU / 8.0K / TOTAL	20 /
▽	NEW CHROME HORIZONTAL SIDEWALL SPRINKLER	1/2" / 165° / QR / 5.5K / TOTAL	6 /
○	New Extended Coverage Pendent Semi Recessed	3/4" / 155° / SSP / 11.4K / TOTAL	28 /
●	QR New Chrome Pendent Sprinkler Quick Response	1/2" / 155° / QR / 5.5K / TOTAL	10 /
●	ES New ESFR Upright Sprinkler	1" / 155° / ESFR / 25.2K / TOTAL	30 /
—	EXISTING PIPE		
—X—X—X—	EXISTING PIPE TO BE REMOVED		
—	NEW PIPE		
	2-HOUR RATED FIRE WALL		
	1-HOUR RATED FIRE WALL		

## TYPICAL SPRINKLER LEGEND



<b>FIRE PROTECTION</b>	
Town of Hope Mills, North Carolina	Detail FP-9 February 28, 2015 Original