

GALVANIZED STAKE  
REFER TO MANUFACTURER'S  
RECOMMENDATION FOR  
INSTALLATION

ALUMINUM EDGE RESTRAINT

BRICK OR  
CONCRETE PAVER  
2 3/8" (60 MM) MIN. THICKNESS

1" TO 1 1/2" (25 - 40 MM)  
COMPACTED BEDDING SAND

VARIABLES

4" (100 MM) MIN. THICKNESS  
COMPACTED AGGREGATE BASE

COMPACTED SOIL SUBGRADE

**SECTION 1**

CONCRETE CURB  
SET 1/4" (7 MM) BELOW TOP OF PAVERS  
AND CONTROL JOINTS @ 15' (4.58 M) OC

BRICK OR  
CONCRETE PAVER  
2 3/8" (60 MM) MIN. THICKNESS

1" TO 1 1/2" (25 - 40 MM)  
COMPACTED BEDDING SAND

4" (100 MM) MIN. THICKNESS  
COMPACTED AGGREGATE BASE

COMPACTED SOIL SUBGRADE

**SECTION 2**

DETAIL NOT TO SCALE

- NOTES:
1. BRICK OR CONCRETE PAVERS ALLOWED ONLY UNDER SPECIAL CONDITIONS.
  2. THICKNESS OF BASE MAY VARY WITH SUBGRADE/TRAFFIC CONDITIONS.
  3. SCATTER SAND OR SCREENINGS OVER COMPLETE WORK AND SWEEP INTO CRACKS.
  4. CONCRETE PAVERS SHOULD CONFORM TO REQUIREMENTS OF ASTM C-1319.
- BRICK PAVERS SHOULD CONFORM TO REQUIREMENTS OF ASTM C902-95.

**CONCRETE/BRICK PAVER SIDEWALK DETAIL**

**STREET DESIGN**

Detail ST-10

Town of Hope Mills, North Carolina

February 28, 2015 Original

