

Dry Detention/Pond Annual Inspection
Town of Hope Mills, NC

Site Name: _____ Date: _____

Code Key
 SF-Satisfactory, no problems noted
 WN-Work needed
 NF-Not functional
 MON-Monitor (potential exists for future problems)
 NA-Not applicable

Inlet

Item assessment	Code	Comments
Condition of pipe or swale		
Evidence of erosion		
Evidence of obstruction		
Other (describe)		

Forebay

Item assessment	Code	Comments
Sediment/debris accumulation		
Evidence of erosion		
Invasive vegetation		
Other (describe)		

Main Treatment Area

Item assessment	Code	Comments
Banks mowed/ no overgrown vegetation		
Invasive/unwanted vegetation		
Sediment accumulation		
Evidence of erosion		
Standing water-drawn down must be between 48-120 hours after storm event		

Other (describe)		
------------------	--	--

Perimeter/Side Slopes

Item assessment	Code	Comments
Debris/sediment accumulation		
Evidence of erosion		
Woody vegetation		
Banks/surrounding area mowed		
Other (describe)		

Outlet

Item assessment	Code	Comments
Obstructed pipe/trash rack/orifice		
Condition of pipe or swale		
Evidence of erosion		
Condition of rip rap		
Condition of emergency spillway		
Other (describe)		

Miscellaneous

Item assessment	Code	Comments
Clear of trash and debris		
Embankment inspected for dam safety		
Inspection of all valves/mechanical devices		
Evidence of routine maintenance		
Other (describe)		

Photographs

Attach digital photographs of the site and BMP features showing the condition of the site at time of inspection.

