



NOTE: SEE NFPA 13 FOR CONNECTIONS PASSING THROUGH OR UNDER FOUNDATION WALLS.

PERMANENTLY CONNECTED HEAT CONNECT TO BUILDING FACP

DETAIL NOT TO SCALE

SPRINKLER RISER

FIRE PROTECTION

Detail FP-4B

Town of Hope Mills, North Carolina

February 28, 2015 Original

